

**Office of the
Superintendent of Police
Lower Subansiri District, Arunachal Pradesh**


No. FSC/SP-ZIRO/10/2026

Dated: 7th May 2026

FIRE SAFETY CERTIFICATE

Certified that the RCC Building at Lempia village, Lower Subansiri district, Arunachal Pradesh comprised of 130 feet x 36 feet basement(s) and 130 feet x 36 feet (upper floors) owned by Ziro Valley School have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified by the officers concerned of Fire Service on 3rd June 2026 in the presence of Mr. Rubu Tadii, chairman Ziro Valley School and that the building/ premises is fit for occupancy upto classes X With effect from **7th May 2026** for a period of 3 years in accordance with rule and subject to compliance of specific conditions as appended:-

1. All fire extinguishers, fire alarms and firefighting equipments installed in the school building shall be maintained in proper working condition at all times.
2. The school management shall conduct periodic fire safety inspection, mock drills and awareness program for students, teachers and staffs regularly.
3. Emergency exit routes, staircases and entry/exit gates shall always remain free from obstruction properly marked with emergency signage.
4. Electrical wiring, electrical installations and appliances shall be checked periodically by competent authority and any defect noticed shall be rectified immediately.


O.C, FIRE SERVICE
L/Subansiri District (A.P)
Ziro
Officer In-charge
Fire Station, Old Ziro
Lower Subansiri District
Arunachal Pradesh

To
Ziro Valley School, Lempia
Lower Subansiri District
Arunachal Pradesh